



national treasury

Department:
National Treasury
REPUBLIC OF SOUTH AFRICA

Strategic Sourcing Enquiries: NT Tender Admin

Email: NTAdministrativetenders@Treasury.gov.za

Ref: RFQ0004-2025

QUESTIONS AND ANSWERS

RFQ0004-2025: APPOINTMENT OF A SERVICE PROVIDER TO INSTALL, CONFIGURE, SUPPORT AND MAINTAIN AUDIOVISUAL/VIDEO CONFERENCING EQUIPMENT FOR THE NATIONAL TREASURY (NT) INFORMATION AND COMMUNICATION TECHNOLOGY (ICT) FOR A PERIOD OF THREE (3) YEARS THROUGH SITA RFB2009

	QUESTIONS	ANSWERS
1.	Cable Routes and USB-C Ports Will National Treasury provide cable routes in each meeting room and include USB-C charging ports?	Allowance has been made for 35mm Conduits in the meeting rooms to enable for separate conduits for AV and Electrical.
2.	Meeting Pods Are AV solutions required for the meeting pods, and should these be Microsoft Teams Room or Bring Your Own Meeting systems?	The building will mainly be an open plan space, so the pods are intended for a single person to have a meeting on their laptop, away from their desk.
3.	Large Room Reinforcement and Cabling For larger rooms with big displays, will the walls be reinforced to support the weight, and will cable routes be provided from the ceiling/floor and to the centre of tables?	Some of the large rooms are mostly surrounded by glass, so displays may be mounted on alternative support such as floor standing or roof mounted rigging. For cable routes (see question 1).

	QUESTIONS	ANSWERS
4.	Large Venues Confirmation Please confirm if the large venues are: 1 x Multifunction Room, 1 x Auditorium, 1 x Training Room, and 1 x Conference Centre.	High-Capacity Rooms <ul style="list-style-type: none"> • Conference Centre (76-seater) • Auditorium (70-seater) • Multi-Function Room (70-seater)
5.	Display Sizes What LED screen sizes should be provided for the Multifunction Room and the Conference Centre?	Included in TOR and spreadsheet.
6.	Confidence Monitors Can confidence monitors for presenters be included in the Multipurpose Room setup?	These will be acquired separately.
7.	Alternative Boardroom Solutions Can service providers propose boardroom solutions that do not include a sound bar?	For boardroom aesthetics, soundbars are the only preferred choice.
8.	Interactive Boards Are interactive boards acceptable as replacements for sound bar video conferencing units?	Interactive boards are not part of the scope.
9.	Power and AV/VC cables Can the power and AV/VC cables share the same conduits in the new buildings?	It is not good practice for electrical and AV/VC to be in the same conduit. We have allowed for 35mm Conduits in the meeting rooms to make allowance for separate conduits for AV and Electrical.



KOENA MAPOTSE
Director: Supply Chain Management
18 November 2025